

Clean

Water

of New York, Inc

Earth Friendly Methods of Recycling

Clean Water of New York, Inc.

Wastewater Acceptance Criteria

The following are the basic acceptance parameters for incoming material at Clean Water of New York, Inc. Clean Water is a fully permitted and insured USCG & NYS DEC Part 360 facility with the authorization and capacity to accept oily water, used oils and oily debris. Procedures and techniques will conform to all applicable local, state and federal regulations.

Basic acceptance parameters

- Flash Point > 100 °F
- Halogens < 1000 PPM
- Solids 1 % (Higher percentages are acceptable at additional cost)
- PCB's* < 2 PPM
- Arsenic < 100 PPM
- Cadmium < 20 PPM
- Chromium < 100 PPM
- Lead < 100 PPM

*Any waste stream originating from a Utility must have PCB analysis submitted with the profile form.

All waste streams must be submitted on a waste profile form for approval prior to shipment.

Normal delivery hours are 7 AM – 4 PM Monday through Friday. Please call to schedule deliveries.